



Notes:

Weight approx: Tank Only 3400 lbs.
 Tank & 3" Lid 3950 lbs.
 Tank & 8" Lid 4200 lbs

State approval number: 16-065-05S-C4
 This tank complies with Chapter 64E-6 Florida Administrative Code.
 Drawing Not to Scale..

525 Gallon Single Compartment Tank

**Tank: 525 Gallon C4 Single Compartment Tank
 Reinforced with Fiber & #4 Steel 12" O/C Both Ways.
 2.5" Walls & 2.5" Bottom.**

**Lid: 3" or 8" Lid w/ 1-24" Manhole Cover. Lid reinforced
 w/ grade #4 Rebar on 12" centers each way.
 Tank & Lid 5000 PSI Concrete at 28 Days.**



**8300 W. Beaver St.
 Jacksonville, FL 32220
 PH. 904.781.4818
 Fax 904.783.3197**