



Notes:

- Weight approx: Tank Only 4500 lbs.
- Tank & 3" Lid 5350 lbs.
- Tank & 8" Lid 6000 lbs

State approval number: 16-065-02D-C4
 This tank complies with Chapter 64E-6 Florida Administrative Code.
 Drawing Not to Scale.

750 Gallon Dual Compartment Septic Tank

**Tank: 750 Gallon Dual Compartment Tank
 Reinforced with Fiber & #4 Steel 12" O/C Both Ways.
 2.5" Walls & 2.5" Bottom.**

**Lid: 4" Lid w/ 2-24" Manhole Covers at each end. Lid
 reinforced w/ grade #4 Rebar on 12" centers each way.
 Tank & Lid 5000 PSI Concrete at 28 Days.**



**8300 W. Beaver St.
 Jacksonville, FL 32220
 PH. 904.781.4818
 Fax 904.783.3197**